GREAT LAKES COPPER

# PRODUCT SPECIFICATION SHEET

## REFRIGERATION-ACR/MED SERVICE TUBE

Great Lakes Copper Ltd. Refrigeration ACR/MED Service Tube is manufactured to meet all chemical, mechanical, and cleanliness requirements of the current revision of the applicable American Society for Testing and Materials (ASTM) specification. ASTM dimensions are available upon request.

Contact Customer Service Department if information regarding certification to a specific ASTM revision is required.

---

**SEAMLESS COPPER TUBE COILS FOR AIR CONDITIONING & REFRIGERATION FIELD SERVICE** — **ASTM B 280 CERTIFIED**
Soft ACR coils, 1/4” through 1 5/8” O.D.

**SEAMLESS COPPER MEDICAL GAS/AIR CONDITIONING & REFRIGERATION TUBE TYPE L** — **ASTM B 280/B 819 CERTIFIED**
Hard straight lengths 3/8” through 4 1/8” O.D.

**SEAMLESS COPPER MEDICAL GAS TUBE TYPE K** — **ASTM B 819 CERTIFIED**
Hard straight lengths 3/8” through 4 1/8” O.D.

Seamless Copper Tube for medical gas systems and seamless copper tube for air conditioning and refrigeration field service supplied in straight hard lengths are cleaned by alkaline washing or by vapor degreasing per CGA 4.1- 2004 edition section 8 or 9 (referred to in NFPA 99 – 2005 edition paragraph 5.3.10.1.1.1). Tubes are cleaned, dehydrated, purged, nitrogen pressurized and plugged.

REVISED: AUGUST 31, 2026

HRAI MEMBER

NSF CERTIFIED NSF/ANSI 61

Warnock Hersey

CIPH·ICPC MEMBER
Canadian Institute of Plumbing & Heating
L’Institut canadien de plomberie et de chauffage

*Exceeding Customer Expectations*

Great Lakes Copper Ltd. | 1010 Clarke Road | London, ON | N5Y 5S6 | (519) 455-0770
ISO 9001:2015